1	
2	
3	
4	STEPP Verification Report
5	
	Stom Then These Treash Continue Device
6	Storm Fragman Frash Frash Capture Device
7	(TCD) Tested in Accordance with ASTM 3332
8	
9	March 2025
10	
11 12	
12	
13	
15	
16	
17	
18	
19	
20	
21	
22	
25 74	
25	
26	
27	
28	
29	

## **Table of Contents**

31	1.0 Description of the Technology	7
32	2.0 Laboratory Testing	8
33	2.1 Test Setup	9
34	3.0 Performance Claims	14
35	4.0 Testing Results	15
36	4.1 Test Apparatus	15
37	4.1.1 Downstream Sensor Location	16
38	4.2 Statistical Analysis	16
39	4.3 Headloss Testing	17
40	4.3.1 H <sub>0</sub> : There is no significant difference between the 3 runs for each configuration	19
41	4.3.2 H <sub>0</sub> : There is no significant difference between the 2 net lengths	21
42	4.3.3 H <sub>0</sub> : There is no significant difference between the 3 mesh opening sizes	23
43	4.3.4 Net Area Calculations	24
44	4.3.5 Discussion of Hydraulic Results & Analysis	25
45	4.3.6 Scaling Hydraulics	27
46	4.3.7 Hydraulic Bypass	
47	4.4 Percent Restriction Testing	
48	4.4.1 Calculating Percent Restriction	29
49	4.4.2 Percent Restriction Test Results	
50	4.4.3 Discussion of Percent Restriction Results	35
51	4.4.4 Hydraulics Bypass	
52	4.5 Mass Loading (Trash Removal) Testing	
53	4.5.1 Artificial Trash QC	
54	4.5.2 Mass Load Testing Results	
55	4.5.3 Discussion of Mass Load Testing Results	40
56	4.5.3.1 Deviations from Mass Capture Test Procedure in ASTM E3332	41
57	4.5.3.2 Wetted Trash Mass Calculations	41
58	4.5.4 Hydraulic Bypass	
59	4.6 Scour	
60	5.0 Additional Consideration	43
61	5.1 Scaling performance	43
62	5.1.1 Scaling Maintenance Capacity	44
63	6.0 Design Limitations	47
64		

## 65 List of Tables

66	Table 1 – % Restriction at Bypass, 5 ft/s	15
67	Table 2 – Hydraulics Test ANCOVA Results	20
68	Table 3 – ANCOVA Results – $\Delta h$ vs. Opening Size	22

60	Table $A = ANCOVA$ Results b1 vs. Length	22
70	Table 5 ANCOVA Results Ab vs. Mesh Opening Size	
70	Table 6 ANCOVA Results h1 vs. Mesh Opening Size	
71	Table $0 - ANCOVA$ Results III vs. Mesh Opennig Size	
12	Table / – Net Open Area	
73	Table 8 – Critical Unblocked Length at Bypass @ 5 ft/s	
74	Table 9 – ANCOVA of Critical Unblocked Length (CUL) vs. Flow Data	
75	Table 10 – Unblocked Length at Bypass, 5 ft/s (CUL)	
76	Table 11 – % Restriction at Bypass, 5 ft/s Flow	
77	Table 12 – Standard Trash Blend	
78	Table 13 – AQL Incoming Inspection QC Requirements	
79	Table 14 – Average Mass Capture Results – Grate Installed	
80	Table 15 – Average Mass Capture Results – No Grate	
81	Table 16 – Mass of Wet and Dry Trash	
82	Table 17 – Normalized Mass Capacity – Net + Grate	
83	Table 18 – Normalized Mass Capacity – Net Only	
84	Table 19 – Normalized Mass Capacity – Combined Data	
85	Table 20 – Unblocked Area/ft <sup>2</sup> of Opening for Different Hole Sizes	
86	Table 21 – Critical Unblocked Area for Different Net Opening Sizes	
87	Table 22 – Capacity of Nets with 5 MM holes	
88	Table 23 – Capacity of Nets with HI Holes	
89	Table 24 – Capacity of Nets with 1 IN Holes	
	· ·	

## 91 List of Figures

92	Figure 1 – Standard TrashTrap Modules	7
93	Figure 2 – Schematic of TrashTrap	
94	Figure 3 – Test Equipment Layout	9
95	Figure 4 – Prototype Frame and Net	
96	Figure 5 – Test Channel Looking Downstream	
97	Figure 6 – Looking Upstream from the Receiving Pit	
98	Figure 7 – Upstream Pumps	
99	Figure 8 – Downstream Pump	
100	Figure 9 – Sensor Locations	14
101	Figure 10 – Top View of Flow Through a Full Net	
102	Figure 11 – Upstream Elevation for 1 <sup>st</sup> Series of Runs	
103	Figure 12 – Upstream Elevations for 2nd Series of Runs	
104	Figure 13 – Upstream Elevations for 3rd Series of Runs	19
105	Figure 14 – Headloss vs Flow, All Data	
106	Figure 15 – Headloss vs Flow, Data to 3000 gpm	
107	Figure 16 – $\Delta h$ vs. Velocity, Data to 7 cfs (3000 gpm)	
108	Figure 17 – Plugs Used for % Blockage Test	
109	Figure 18 – Top View of % Restriction Test Run	
110	Figure 19 – 2FT 5MM Net % Restriction Test	
111	Figure 20 – 2FT HI Net % Restriction Test	
112	Figure 21 – 2FT 1IN Net % Restriction Test	
113	Figure 22 – 4FT 5MM Net % Restriction Test	
114	Figure 23 – 4FT HI Net % Restriction Test	

115	Figure 24 – 4FT 1IN % Restriction Test	34
116	Figure 25 – 2FT 1IN Net % Restriction Test h1 Data	35
117	Figure 26 – Bypass of 2FT 5MM Net	41
118	Figure 27 – Flow Rate During Scour Tests	43
119		

## 120 List of Appendices

121	Appendix I – 3 <sup>rd</sup> Party Observer Resume and Statement of Qualification	
122	Appendix II – ANCOVA Discussion	51
123	Appendix III – Hydraulics Data	See Separate Document
124	Appendix IV – Hydraulics ANCOVA	See Separate Document
125	Appendix V – Net Blockage Data	See Separate Document
126	Appendix VI – Unblocked Length Data	See Separate Document
127	Appendix VII – ANSI/ASQ Sampling Charts	See Separate Document
128	Appendix VIII – Mass Loading Data	See Separate Document
129		

## 130 Abbreviations and Definitions

#### 

Abbreviation/Term	Definition
COV	Coefficient of variance
MDL	Method detection limit
MQL	Method quantification limit
MTD	Manufactured treatment device
MTFR	Maximum treatment flow rate
PSD	Particle size distribution
QAPP	Quality assurance project plan
RPD	Relative percent difference
SSC	Suspended sediment concentration

#### 135 [1] Revision Table

## 136

	Revision Number	Reason for Revision	
	1	Initial document revision	
137			
138			
139			
140	Approvals		
141			
142	StormTrap LLC (Applican	t):	
143			

Greg Williams Director of Water Quality Technology

144

#### 145 Independent Observer:

146

Jason Wiesbrock, P.E., SpaceCo Inc.

#### 147

- 148 **STEPP:**
- 149

Seth Brown Executive Director

150

151

Date

Date

Date

# 152 **1.0 Description of the Technology**

StormTrap TrashTrap® netting systems combine the natural energy of water flow with disposable mesh nets to capture and retain trash, floatables, and solids from stormwater and wastewater. The systems can be adapted to a variety of applications. TrashTraps can be connected in parallel or series to handle a wide range of pipe or channel sizes and flow rates. TrashTraps have three different standard modules, and several net assembly sizes are available for each. Modules are the same in all critical respects. Only the outside structure is different, and independent of the system's performance (Figure 1). The three different modules are:

- The In-Line TrashTrap modules are installed underground and upstream of the outfall.
   Components are installed in a high-strength precast concrete chamber, and servicing the unit is done at ground level.
- The End-of-Pipe TrashTrap modules are utilized where the end of the collection system enters the water course. Components can be installed into a new headwall or retrofitted to existing outfall structures.
- The Floating TrashTrap modules perform in the same manner as End-of-Pipe systems, but
   they float on the water. Components are installed in a pontoon structure that floats constantly
   at water level, and, if equipped, funnel and side curtains direct trash into mesh nets.
- 169

## **Figure 1 – Standard TrashTrap Modules**



- 170 171

172 Figure 2 shows a TrashTrap in an in-line configuration. A guiderail is used to secure the TrashTrap

to the structure. It contains a groove into which a net assembly can be inserted. Each net assembly is

174 comprised of a net that is attached to a frame at the opening that keeps the mouth of the net open and

allows the net to be secured to the guiderail. In some installations a LiftMaster is included in the

176 design. A LiftMaster is a component that encompasses the net assembly and aids in the lowering and

177 raising of the net when performing maintenance activities. For clarity, some of the LiftMaster has

178 been removed from the figure.

179 The TrashTrap is designed to bypass the very high flows that can occur during large storms.

180 Captured debris is contained in the netting assembly and is unaffected by the water surface elevation

181 within the system. The grate is an optional component that allows for some floatable capture at the

182 netting assembly bypass flows. Captured debris is retained upstream of the grating unless the water

183 surface elevation exceeds the top of grating elevation. If the water surface elevation does not surpass

the grating, after the precipitation event subsides, and the water level recedes, captured debris will

185 migrate into the net.





- 189
- 190

## 191 **2.0 Laboratory Testing**

192 Testing was conducted at a temporary laboratory facility located in Morris, Illinois in September and

193 October of 2023. The facility is described in more detail in Section 3. The third-party observer was

Jason Wiesbrock, P.E., Vice President of Space Co. Inc. Mr. Wiesbrock is responsible for managing

195 the Morris, Illinois office of SpaceCo.

196 Mr. Wiesbrock has a BSc in Civil Engineering from the University of Illinois and he is a Professional

197 Engineer in the state of Illinois. He has nearly 30 years experience, including stormwater

198 management projects and regulatory compliance work, and he has been called on as an expert witness

199 on civil engineering projects. His resume and statement of qualification is included in Appendix I.

200 The net assembly variables affecting performance include frame aperture size, net length, and netting

201 mesh opening size. All commercial net assembly frames are larger than the 12"x12" aperture that

202 was tested. The smaller aperture was chosen to simplify scaling calculations and to limit the flow

required. TrashTraps are typically designed for a flow velocity of 5 ft/s so a 1' x 1' net is designed

for 5 cfs, which was near the limit of our pumping capacity, so a larger aperture was not practical.

205 Testing was conducted in accordance with ASTM 3332 "Standard Test Method for Determining

206 Trash and/or Debris Capture Performance of Stormwater Control Measures", except for Sections 9.4

and 9.6. Tests for Trash and Debris, and 5 mm beads were not conducted, and no claims will be

208 made.

- 209 It was assumed that performance will scale with net surface area so that the frame aperture (12"x12")
- 210 need not be varied. This was confirmed during testing as explained later in this report. Two net
- 211 lengths and all three commercially available hole opening sizes (5mm, ½", 1") were tested.
- 212

## 213 **2.1 Test Setup**

The laboratory test set-up was a water flow loop, capable of moving water at a rate of up to 7 CFS.

- 215 The test loop, illustrated in Figure 3, is comprised of water reservoirs, pumps, valves, test channel,
- 216 receiving pit, flow meters, level sensors and a thermometer.
- 217 The device tested was a commercially available net attached to a square wooden frame with a 1' by 1'
- cross sectional open area, which will be called the aperture throughout this report (Figure 4). The
- total width and height of the net/frame assembly was 15". The frame was made from standard 2 x 4s,
- so the opening (aperture) size was 12" x 12" and the depth of the frame, in the flow direction, was 3.5
- inches. The frame was fitted into a metal C channel that was secured at the end of a 15" wide by
- 41.5" high channel such that when the frame was installed the exposed frame was 13" x 13". Since
- the aperture was 12" x 12", this resulted in an open area equal to 92% of the cross section of the net
- and frame assembly, which is equal or less than the open area of commercial configurations.
- 225 This means the test set up was conservative from a hydraulics perspective. Commercial systems
- would have an equal or larger aperture compared to the frame assembly and thus would create less
- headloss.
- 228







232

In the test flow loop, potable water was pumped from the storage tanks by a pump from Rain for

Rent. The pump was Rain for Rent #610374 Engine: Perkins 2952/2200 serial #PJ38440. Pump:

PowerPrime DV200C serial #108197. For the higher flow tests, a second pump was added just

downstream of the first pump. It was the Rain for Rent #619036 with a Perkins engine and a
 PowerPrime DV200C pump, serial #71068N. The outlet pipe from the pump was dropped to the

PowerPrime DV200C pump, serial #71068N. The outlet pipe from the pump was dropped to theground and then raised at the entrance to the test channel in order to ensure that the pipe was always

- full where the flow meter was located. From the test channel, the water flowed into a receiving tank
- where it was pumped out and back into the storage tanks using another pump from Rain for Rent.
- This pump was Rain for Rent #611213 Engine: John Deere 6068HF485 serial #PE6068L141598
- 242 Pump: PowerPrime DV200C serial #2020DV200C-112.

243 Flow measurements were made using a Greyline Time of Transit Flow Meter (TTFM) 1.0 (serial 244 #71418, calibrated 14 June 2023), configured to take readings every 30 seconds. The TTFM was installed with at least 20' of straight pipe upstream and downstream, to ensure the location complied 245 246 with the manufacturer's recommendations. Elevation measurements were taken with 2 point-gage 247 systems adjusted to a known reference, one 2" upstream and one 2" downstream of the guiderail. Both 248 elevation sensors were calibrated by the manufacturer and were verified daily with an engineer's scale 249 ruler. All elevation data was logged on a MadgeTech Titan S8 serial #S49796, configured to record all 250 channels simultaneously at a rate of once every 30 seconds. The thermometer was a MadgeTech 251 MicroTemp serial #Q47774, calibrated 14 June 2023. Temperature was recorded once per minute. 252 Time keeping was done with Traceable stopwatches model 1042, serial #94460-55, calibrated 15 March 253 2023.

- 255 The following are details of the test flow loop:
- From the storage tanks, water flowed through 12" pipes, except at the pump which had a 12" inlet and 8" outlet. The outlet was directly attached to an 8"x12" concentric flange to maintain the use of 12" pipe, to the 14" wide, 41.5" deep, 16' long test channel.
- At the end of the test channel an outlet channel flared out to 8' wide and it was 8' long. The outlet channel terminated with a free-fall thru 0.125" screening material affixed directly above the receiving tank.
- The water was pumped back into the storage tanks to complete the flow loop. There was a 12" gate valve upstream of the return pump.
- There were 12" gate valves upstream and downstream of the inlet pump.
- The water storage tanks had a total capacity of approximately 140,000 gallons, 20,000 gallons each, with the option for freshwater make-up.

267 Figure 5 is a view of the test channel looking downstream from on top of one of the water storage tanks. 268 Figure 6 is a view looking upstream from the far side of the receiving pit. The concrete blocks 269 surrounding the channel were installed to provide structural support. The backstop on the far 270 (downstream) side of the receiving pit was intended to prevent any water from jetting over the pit. The 271 channel flares after the net opening in order to mimic a typical end of pipe installation. The width of 272 the channel was 8', so a single sheet of plywood could be used for the flow. The downstream sensor placement was chosen to minimize any possible wall effects, thus rendering the exact channel geometry 273 274 irrelevant.

Figure 7 shows the two upstream pumps used to deliver the flow. The second pump was added for the scour test. Figure 6 shows the downstream pump, which drew water from the receiving pit and returned it to the tanks. Figure 7 shows the location of the two sensors. Both sensors are float types with a hole in the floor of the channel that allows a plastic tube to fill and raise the float. The upstream opening is in the centerline of the channel where the tube in the middle left of the figure is sticking out. The downstream opening is visible in the lower left of the picture. The tube for the downstream sensor is just out of the frame.

- 282
- 283
- 284
- 285
- 286
- 287
- 288
- 289
- 290

- 292
- \_\_\_\_
- 293
- 294



Figure 6 – Looking Upstream from the Receiving Pit



## Figure 7 – Upstream Pumps



Figure 8 – Downstream Pump





- 315
- 316
- 317
- 318

# 319 **3.0 Performance Claims**

320 The following are the performance claims made by StormTrap LLC. They are based on the

independently verified laboratory test results described in more detail in Section 4.

#### 322 Hydraulics

Based on the analysis of 168 runs we were able to conclude that headloss is not a significant function of net length or hole opening size, so we claim the following relationship for headloss, in inches, as a

- 325 function of flow velocity, in ft/s, across our product line (Equation 18):
- $326 \qquad \Delta h = 0.91176^* v + 0.07010$
- 327
- 328 % Restriction
- 329 TrashTrap hydraulics are practically unaffected until a certain amount of netting mesh open area is
- 330 reached. At this point, bypass occurs. This critical area does not change with net length so %
- 331 restriction is a function of net length, as shown in Table 1 below.

Net length (ft)	Critical % Restriction
2	75%
4	88%
6	92%
8	94%

#### Table 1 – % Restriction at Bypass, 5 ft/s

333

334 Trash Removal

Removal was 100% up to the point of bypass for all the nets tested. Mass capacity was not found to

- be a function of hole opening size. The average mass capture was  $2.64 \text{ lbs/ft}^3$  of net volume.
- 337 Maintenance Capacity
- All nets should be emptied when they are  $\leq 85\%$  full.
- 339 Scour

340 TrashTrap nets do not scour any previously captured material at an average of 9.77 ft/s. According to

ASTM E332, this makes it suitable for off-line installation at flow velocities up to the StormTrap  $\frac{242}{100}$ 

recommended limit of 5 ft/s and for on-line installation for velocities up to 4.89 ft/s.

343

# 344 **4.0 Testing Results**

345 Some aspects of E3332 are open to interpretation, and how they get interpreted impacts how results 346 are obtained and subsequently interpreted. This section describes how StormTrap decided to interpret 347 aspects of E3332 and explains why the decisions were made.

## 348 **4.1 Test Apparatus**

349 The language in ASTM E3332 clearly assumes that there will be pipes immediately upstream and

downstream of the test unit, as is typical when testing an HDS or filter. However, piping is not

351 prescribed and since TrashTraps are not typically installed in pipes the decision was made to use a

channel upstream and downstream of the device, as shown in Figure 6, Figure 7 and, Figure 9.

353 Inlet pipe size is not specified beyond the requirement "that at all test flow rates the pipe is in open

354 channel flow". StormTrap chose to make the upstream channel equal to the net opening area plus the

355 width of a standard frame since this is the most representative configuration. The only outlet pipe

- size specification is that it "must be able to accommodate a net or screen at the end of the outlet pipe,
- or at the tank outlet, to allow for capture of any trash in the effluent flow. The net or screen shall not cause water back up into the outlet pipe". StormTrap chose to make the outlet channel flare out
- immediately after the frame to a width large enough that it did not impact the downstream flow.

## 360 **4.1.1 Downstream Sensor Location**

Section 6.5 of E3332 states that the location of the elevation sensors "shall be 1-2 pipe diameters upstream and downstream of the unit". It is assumed, though not stated, that the sensor will be along the centerline. In addition, the standard requires that the location remain fixed for all tests.

364 StormTrap interpreted this to mean 1-2 channel widths upstream and along the centerline for the 365 upstream sensor. For the downstream sensor a location along the centerline would not work because 366 the net was greater than 2 channel widths long so it would cover the sensor (Figure 10). As the net 367 filled, this would block off any downstream readings. In order to have a location that was logical and 368 reproducible, and which would not be affected by the downstream channel geometry, a point in line 369 with the frame 2 channel widths downstream was chosen (Figure 9).

370



371

## 372 4.2 Statistical Analysis

ASTM E3332 provides little guidance on how to analyze all the data that is generated. As with the test apparatus, this required interpretation of the requirements to provide a reasonable analysis of the results.

For example, Section 9.1.4 requires that, for the three runs that generate elevation versus flow data, the elevations at a given flow be within 10% of each other. However, 6.4.1 allows the flow to vary

 $\pm 10\%$  around the target. The result is that, even if the system has identical elevation versus flow

behaviour all three times, the elevation data could be out of spec due to in spec variation in flow. The

- 380 result would be a false negative, rejecting data that should be accepted. This is particularly a problem
- at low flows, which are challenging to reproduce, and which yield small elevations that are difficult
   to measure accurately.
- In addition, a point-by-point comparison between runs ignores the fact that the points within a run should fall on a curve. Rigorous analysis requires that the data be compared within runs as well as between runs. There is a statistical method that can be used to determine if multiple curves, not just points, are the same. This method, analysis of covariance (ANCOVA), accounts for the fact that flow is not always exactly on target and therefore provides a more realistic analysis. ANCOVA does not provide a + 10% result but it is more rigour and weeful so it was chosen for this report.
- provide a  $\pm 10\%$  result but it is more rigour and useful, so it was chosen for this report.
- 389 It is possible to perform ANCOVA with the Regression function in Excel, which is part of the Data
- 390 Analysis Add-On. This add-on is free. Appendix II provides a brief summary of how ANCOVA is
- 391 used.
- 392 This report uses ANCOVA where comparison of curves is required, such as in headloss testing.
- 393 Where multiple runs generate a single point each, such as the mass capacity testing, only a mean and
- 394 percent difference is reported. Three total data points is not sufficient data for a meaningful 95%
- 395 confidence interval.

## 396 **4.3 Headloss Testing**

- 397 Hydraulic testing was conducted in accordance with section 9.1 of ASTM E3332. Water surface
- elevations were recorded at 10, 25, 50, 75, 100, and 125 % of MTFR, then at 25 % increments up to
- 399 200%. The pumps maxed out at 175% MTFR so each curve has 8 points. Since nets are
- 400 commercially available with three mesh opening sizes, 5 mm, 0.5" and 1", and with variable length, 401 six different net configurations were tested, along with a control. This resulted in 7 x 8 x 3 = 168 data
- 402 points.
- 403 The naming convention used for the different net configurations is "LENGTH MESH SIZE". For
- 404 example, a 4' net with 1" holes is 4FT 1IN and a 2" net with 5 mm holes is 2FT 5MM. Any baseline
- 405 runs with no net are labelled CONTROL and HI denotes 0.5".
- Figures 10-12 show the upstream elevation for each of the three series of runs. Section 12.7.1 requiresreporting velocity head vs. flow rate. Velocity head is given by Equation 1.

# 408 Equation 1 $h_v = \frac{v^2}{2a}$

- 409  $h_v = \text{head (ft)}$
- 410  $v^2 =$ velocity (ft/s)
- 411  $g = \text{gravitational constant (ft/s^2)}$
- 412 Given that the baseline elevation is set at 0, the total elevation is effectively velocity head so Figure
- 413 11 through Figure 13 meet the requirement of 12.7.1.
- 414
- 415
- 416
- 417



Figure 12 – Upstream Elevations for 2nd Series of Runs





426 The data was then analyzed using ANCOVA to test three basic hypotheses:

- 427 1. H0: There is no significant difference between the 3 runs for each configuration
- 428 2. H0: There is no significant difference between the 2 net lengths
- 429 3. H0: There is no significant difference between the 3 mesh opening sizes

430 These hypotheses were chosen based on the overall physical hypothesis that the headloss coefficient, 431 k<sub>L</sub>, only increases when the mesh open area of the net, i.e. the sum of the area of all the holes, is less 432 than the aperture area, i.e. the mouth of the net. The rationale for this is that if the opening area is 433 greater than the aperture area then the net does not provide any extra restriction of the flow and thus

434 should not increase headloss.

Each analysis is discussed in separate sections below. Given the large amount of raw data, it is notincluded here but can be found in Appendix III and Appendix IV.

# 437 4.3.1 H<sub>0</sub>: There is no significant difference between the 3 runs for each 438 configuration

439 The TrashTrap is commercially available in multiple combinations of net length and opening size.

440 For this report, 6 net configurations were tested, consisting of two different net lengths and three

441 opening sizes. A control run with no net was also completed, for a total of 7 configurations. The

442 ASTM standard requires each configuration to be tested at 7 flows on three separate occasions. We

- 443 chose to do 8 because we hate ourselves. This resulted in 24 data points for each configuration, for a
- total of 168 data points.

- 445 The first null hypothesis to be tested is H<sub>0</sub>: each run for a given configuration is the same. In other
- 446 words, the test apparatus produces repeatable results. This will allow the three separate datasets for
- 447 each configuration to be collapsed into one dataset for further analysis.
- 448 For this analysis the method looks at the dependent (y) variable = headloss, as a function of the
- 449 dependent variable (x) = series of runs (1, 2 or 3) with flow rate (Q) as the covariate. Table 2 shows
- 450 the results of ANCOVA for the three sets of data for each configuration shown in Appendix III.
- 451 The p value in the table indicates the probability that the variable is significant. If p < 0.05 the
- 452 variable is significantly different than the reference and the null hypothesis,  $H_0$  is rejected. If p > 0.05
- 453 H<sub>0</sub> is accepted and the variable is not significant. In the following Table 2, the reference for Intercept
- 454 and Flow is 0 while the reference for Series 1 & 2 is Series 3.
- 455 Significant results are indicated in **bold**. This means that the null hypothesis is rejected and any bold
- 456 values for Intercept indicate a no-zero intercept, any bold values for Series 1 or 2 means that Series is
- 457 not the same as Series 3 and any bold values for Flow means it is a significant factor in explaining the
- 458 hydraulics curve. Table 2 shows that the only factor significantly affecting headloss ( $\Delta$ h) was flow 459 rate, independent of what series was analyzed.
- 460

Configuration	p for Intercept	p for series 1	p for series 2	p for Q
CONTROL	0.00	0.60	0.88	0.00
2FT 5MM	0.58	0.41	0.53	0.00
2FT HI	0.098	0.98	0.91	0.00
2FT 1IN	0.43	0.72	0.40	0.00
4FT 5MM	0.21	0.54	0.63	0.00
4FT HI	0.0061	0.56	0.95	0.00
4FT 1IN	0.091	0.70	0.95	0.00

Table 2 – Hydraulics Test ANCOVA Results

For every configuration  $H_0$  is accepted, the three hydraulics runs were statistically the same. Two of the intercepts were not 0, the control and the 4FT HI, which is unexpected since headloss at zero flow should be zero inches. The equations below will show that all the intercepts are close to zero. The fact they are not exactly zero is an artifact of regression analysis. They could be forced to zero and the R<sup>2</sup> values would still be very good, where  $\geq 0.9$  is generally accepted as very good for pilot scale testing, but they were left as is in this report.

This analysis meets the intent of ASTM E3332. It also allows the data sets to be combined to form a
single equation for headloss versus flow for each configuration, thus reducing 21 equations to 7
equations. These equations are:

472	Equation 2	CONTROL:	$\Delta h = 0.00155 * Q + 0.684, R^2 = 0.98$
473	Equation 3	2FT 5MM:	$\Delta h = 0.00222^*Q - 0.175, R^2 = 0.99$
474	<b>Equation 4</b>	2FT HI:	$\Delta h = 0.00173^*Q + 0.266, R^2 = 0.98$

475	Equation 5	2FT 1IN	$\Delta h = 0.00217 * Q + 0.247, R^2 = 0.97$
476	Equation 6	4FT 5MM:	$\Delta h = 0.00164 * Q + 0.302, R^2 = 0.91$
477	Equation 7	4FT HI:	$\Delta h = 0.00130^*Q + 0.875, R^2 = 0.88$
478	<b>Equation 8</b>	4FT 1IN	$\Delta h = 0.00150 * Q + 0.631, R^2 = 0.90$

480 In every case the fit is very good or good, with the fit for the control and the 2FT net being slightly 481 better than for the 4FT net.

482 It should be noted that linear equations are consistent with the physics of flow. From Manning's 483 equation for open channel flow,  $v = f(Q^{1/2})$  and from Bernoulli  $h = f(v^2)$  so h = f(Q) and a linear relationship is expected. To be thorough, the data was also fit to a second order equation.  $R^2$  did 484 485 increase in some cases but since  $R^2$  was already > 0.9 the improvement was not significant. As a rule, the lowest order polynomial with acceptable fit is preferred. This is supported by the fact that 486 some of the equations had  $\Delta h = f(-flow^2)$ , which does not make physical sense. Headloss should not 487 488 go down at higher flow. For these reasons the second order equations were discarded in favour of

489 first order equations.

The conclusion to be drawn from this analysis is that each of the three runs for a given configuration 490

491 gave the same result. This will allow for the collapse of some data. It also indicates that the test

492 setup and instrumentation are reliable.

#### 4.3.2 $H_0$ : There is no significant difference between the 2 net lengths 493

494 Having demonstrated in the previous section that each of the three runs for a given configuration is

495 the same, it was possible to collapse the 21 datasets into seven datasets, one for each configuration,

496 for further analysis. The next most important effect is that of net length. If the null hypothesis is 497 accepted the seven equations from the previous section can be reduced to four (control plus each

- 498 netting mesh size).
- 499 The null hypothesis to be tested is H<sub>0</sub>: for a given net mesh size, headloss is not a function of net 500 length
- 501 For this analysis the method looks at the dependent (y) variable = headloss, as a function of the

502 dependent variable (x) = net length with flow as the covariate. There is reason to believe that opening

503 size will be a factor so the different opening sizes will not be combined for this analysis. As a result,

504 there will be three ANCOVA results in this section. These are shown in Table 3.

505 As with Table 2, the p value in the table indicates the probability that the variable is significant. If p 506 < 0.05 the variable is significantly different from 0, otherwise it is not. Note that significant results are, again, indicated in **bold**. Table 3 shows that, as expected, flow is a factor in headloss for all three 507 508 opening sizes. The fact that length is a factor in two cases is surprising, particularly since it is a 509 factor for the largest and smallest opening but not the intermediate ones. Given the large total mesh 510 open area of all the nets, compared to the aperture area, length would not be expected to be a factor. 511 If there was a difference it would be expected to show up at one extreme of opening size, not in the

- 512 middle.
- 513
- 514
- 515

Table 3 – ANCOVA Results – Ah vs. Opening Size

Configuration	p for Intercept	p for length	p for Flow
5MM	0.18	0.00	0.00
HI	0.01	0.14	0.00
1IN	0.94	0.00	0.00

518 In this case H<sub>0</sub> is rejected 6 out of 9 times, which suggests an issue with the data. Based on

519 observations, it is likely that the issue was with the downstream sensor. It was in a fixed location, but

520 the flow pattern changed from the 2FT net to the 4FT net. The end of the 2FT net is near the sensor

521 location creating a wave that raises the elevation in that location. This is discussed in more detail in 522 Section 4.1.

522 Section 4.1.

523 An ANCOVA test was conducted using just upstream elevation, to determine if the downstream

elevation data is the problem or not. Table 4 shows the ANCOVA results using upstream elevationinstead of headloss.

526

 Table 4 – ANCOVA Results – h1 vs. Length

Configuration	p for Intercept	p for length	p for Flow
5MM	0.00	0.11	0.00
HI	0.00	0.83	0.00
1IN	0.00	0.40	0.00

527

528 This data matches expectations, flow rate is a significant factor in upstream elevation, but net length

529 is not. The fact that removing the downstream data eliminated the effect of length supports the

hypothesis that the downstream sensor location is creating false significance and that hydraulics is infact independent of length, despite the results in Table 3.

532 This allows the length data to be combined to create 1 equation for each opening size that replaces the 533 equations in section 3.2.2.1.

534

535 The new headloss equations are:

536	Equation 9	5MM:	$\Delta h = 0.00193 * flow + 0.0637, R^2 = 0.92$
537	<b>Equation 10</b>	HI:	$\Delta h = 0.00151*flow + 0.570, R^2 = 0.92$
538	<b>Equation 11</b>	1IN:	$\Delta h = 0.00182^* flow + 0.485, R^2 = 0.87$

539

540 The  $R^2$  values are slightly lower than for the corresponding separate equations (Equation 3)

541 & Equation 6, Equation 4 & Equation 7, Equation 5 & Equation 8) but they are still relatively good.

542 Despite the fact that the downstream elevation was re-introduced, and it is known from Table 3 that

this data contains significant sensor error, the goodness of fit suggests that Equation 9-Equation 11

- are usable. It is desirable to have the equations in terms of headloss because it is a useful number in
- 545 hydraulic system design.
- 546 To double check the downstream sensor error hypothesis, regression was performed on the combined
- 547 upstream elevation data, once again removing the effect of the downstream elevation error. The 548 resulting equations are:

549	Equation 12	5MM:	$h1 = 0.00224$ *flow + 0.693, $R^2 = 0.99$
	1		

- 550 Equation 13 HI:  $h1 = 0.00208*flow + 0.890, R^2 = 0.98$
- 551 Equation 14 1IN:  $h1 = 0.00201*flow + 1.02, R^2 = 0.96$

552 It can be seen that the fit is better when looking at upstream elevations only, so the downstream data 553 is introducing error, but the error is small. One way to quantify the error in the downstream elevation 554 data is to note that the difference in slope between the two sets of lines is less than 0.001 in/gpm and 555 the intercepts, which should be 0, are within 0.75" of each other. These differences will not have a 556 practical impact in a real installation. This further supports the decision to use Equation 9-Equation 557 11 instead of Equation 12Equation 14.

# 4.3.3 H<sub>0</sub>: There is no significant difference between the 3 mesh opening sizes

For this analysis, the three different mesh sizes are compared at each length. This results in a 3 factor ANCOVA, similar to the hydraulics analysis, and not a 2 factor ANCOVA, similar to net length. In this three factor ANCOVA, the reference series is the 1 IN mesh data. The expectation, based on physical reality, is that  $H_0$  will be accepted, the difference in mesh sizes is not great enough to have an effect. The results of the analysis are shown in Table 5.

565

Table 5 – ANCOVA Results Δh vs. Mesh Opening Size

Configuration	p for Intercept	p for 5MM	p for HI	p for Flow
2FT	0.00	0.016	0.00	0.00
4FT	0.00	0.76	0.42	0.00

566

In this case the results are, again, unexpected.  $H_0$  is rejected 6 out of 8 times, The expectation was that mesh size would not be significant, based on the large total mesh open area for all sizes, and that this would be true for both lengths, based on the conclusion from the previous section that length is not a factor. The analysis shows that mesh opening size is significant for the 2FT nets but not for the 4FT nets.

- 572 The analysis in the previous section provides one possible explanation: that the downstream data is
- 574 575

573

at only the upstream elevation data.

Table 6 – ANCOVA Results h1 vs. Mesh Opening Size

inconsistent due to the static position of the sensor. Once again, this effect was examined by looking

Configuration	p for Intercept	p for 5MM	p for HI	p for Flow
2FT	0.00	0.00	0.23	0.00
4FT	0.00	0.13	0.55	0.00

- 577 Eliminating the 'noise' from the downstream elevation data results in only 1 configuration being
- 578 significant, the 2FT 5MM net. This might be explained by the fact that, of all the configurations, the
- 579 2FT 5MM net has the smallest total mesh opening area. This hypothesis is examined in more detail 580 in the following section.

## 581 4.3.4 Net Area Calculations

582 The physical explanation for the hypotheses in 4.3.2 and 4.3.3 is that, as long as the mesh open area, 583 the sum of all the hole opening areas, is greater than the aperture area then it should not matter how

584 much greater. In other words, increasing net length above a certain minimum and increasing mesh

585 open area above a certain minimum should not have an impact on headloss. The following

586 calculations provide the numbers needed to evaluate this explanation.

587 Due to the method of attachment to the frame, the 2FT nets have an available open length of 20",

- 588 while the 4FT nets have an available open length of 44". For the purpose of calculating net area, the
- net is assumed to be a cylinder with the same cross section area as the frame opening,  $1 \text{ ft}^2 = 144 \text{ in}^2$ .
- 590 This results in a cylinder diameter of 13.54 in. Since the net actually stretches and narrows this area
- is slightly overestimated. The fibers comprising the netting are 1/16" thick. This means that the open
- area is calculated as:

593 Equation 15 % open area =  $100^{\circ}$  opening size<sup>2</sup>/(opening size + 0.125)<sup>2</sup>

594 The standard equations for area of a cylinder, and equation 15 above, were used to calculate the 595 values in Table 7.

596

Configuration	Surface Area (in <sup>2</sup> )	% open	Open area (in <sup>2</sup> )
2FT 5MM	851	37	315
2FT HI	851	64	545
2FT 1IN	851	79	672
4FT 5MM	1702	37	678
4FT HI	1702	64	1173
4FT 1IN	1702	79	1448

Table 7 – Net Open Area

597

Table 7 confirms that even the smallest open area,  $315 \text{ in}^2$ , is more than double the aperture area, 144

 $in^2$ , so the hydraulics would be expected to be the same for every configuration. Table 4 supports the

600 conclusion that length is not a factor. Table 5 suggests that hole opening size is a significant factor

but when the downstream sensor issue is accounted for, only one configuration does not fully fit our

602 physical explanation.

603 It is noteworthy that the one significant result was for the shortest net with the smallest hole openings.

604 If any configuration would be significant, our physical explanation would say it is that one. That

said, the mesh open area is more than double the aperture open, which should be enough that there is

no difference, so the balance of probabilities suggests that the physical explanation is correct, and the

607 significant result is an artifact of the data.

608

## 609 4.3.5 Discussion of Hydraulic Results & Analysis

610 Three curves depicting headloss versus flow rate were generated, each with 8 data points, for each of

611 6 net configurations plus a frame only control. Analysis of the 3 curves for each of the 7

612 configurations showed that they were statistically the same so the apparatus generates reproducible

results, and the data can be collapsed from 21 sets to 7.

Based on the fact that all of the net open areas were greater than the aperture area, it was expected that net length and hole opening size would not be significant and the remaining 7 equations could be collapsed into 1. There were some instances where curves were significantly different but there were no trends or indications that the expectation was unreasonable. The significant results could be attributed to some anomalies in the downstream elevation data, that created anomalies in the headloss

data. These can be attributed to the downstream sensor placement as discussed in Section 3.1.1.

After all the analysis, only 1 curve, for the 2FT 5 MM, net was found to be statistically significantly different. Given that it is only 1 of 21 curves, and the frame aperture area should be enough, the

decision was made to treat it as if it was not significant and analyze all the data together. When this

623 was done, Equation 9-Equation 11 could be further collapsed into a single equation, derived from all

624 168 data points.

625		
626	Equation 16	$\Delta h = 0.0017^*Q + 0.4039 \qquad R^2 = 0.90$
627		
628	Where	m = slope
629		b = intercept
630		Q = flow (gpm)
631		$\Delta h$ = headloss across the system (in)
632		
633		
634		
635		
636		
637		
638		
639		
640		



642

Figure 14 shows the curve fit for the headloss data that was used to develop Equation 16. Visual inspection indicates that the less reliable data at higher flow rates is decreasing the slope. A more conservative approach would be to base the headloss equation on the data over the design range of the system, which is 0 - 5 cfs or 0 - 2244 gpm. Dropping the data for flows above 3000 gpm, well in excess of the design flow, results in Equation 17:

651

$\Delta II = 0.00205 Q \pm 0.07010 R = 0$	652 Equation 17	$\Delta h = 0.00203 * Q + 0.07010$	$R^2 = 0.95$
---	-----------------	------------------------------------	--------------

- 653 Where Q =flow rate in gpm.
- The 95% confidence interval for the regression parameters are:
- $655 \qquad m = 0.00195 0.00212$
- $656 \qquad b = -0.0719 0.212$

This is a better fit and a slightly more conservative equation so it will be the one claimed. The datafor Equation 17 is displayed graphically in Figure 15.

- 659
- 660

- 662
- 663



## **4.3.6 Scaling Hydraulics**

669 The result of sections 4.3.1 to 4.3.5 indicates that headloss is simply a function of flow rate, it is not 670 significantly affected by the properties of the net. From the headloss equation it is given that 671 headloss is, in fact, a function of velocity so in order to scale, the flow equation must be converted to 672 a velocity equation, shown graphically in Figure 16. This is simplified by the fact that the opening 673 area is 1 ft<sup>2</sup> so the velocity, in ft/s, is simply equal to the value of the flow in cfs.



690 Equation 18  $\Delta h = 0.91176^*v + 0.07010$  R<sup>2</sup> = 0.95

- 691 Where v =flow velocity in ft/s
- 692 The 95% confidence interval for the regression parameters are:
- $693 \qquad m = 0.873 0.950$
- $694 \qquad b = -\, 0.0718 0.212$
- 695 Equation 18 is the one to be used for calculating headloss for different sized systems.

## 696 4.3.7 Hydraulic Bypass

697 The elevation of the top of the frame was 15.5" above the channel floor. Above this level, flow 698 would be unobstructed so the headloss equation would be expected to change to that of a vertical 699 weir. This effect was not confirmed since, due to pump capacity limitations, the elevations did not 690 get high enough during the headloss testing.

701

## 702 4.4 Percent Restriction Testing

The overall physical hypothesis, introduced in Section 4.3.4, that the headloss coefficient,  $k_L$ , only increases when the open area of the net is less than the aperture area leads to two expected

phenomena during the percent restriction testing. First, as the nets fill there should be a point at

- which headloss increases dramatically and, second, the 'bypass' point should be at the same open area, regardless of net length.
- 708 Percent restriction testing was conducted in accordance with section 9.2 of ASTM E3332, using a
- 709garbage bag filled with discs of Styrofoam to mimic the volume and buoyancy of the appropriate
- amount of trash corresponding to the required fill levels (10, 30, 50, 70 and 90%). This allowed each
- <sup>711</sup> 'plug' to be re-used, increasing consistency and saving time. Based on observations during trial runs
- this method conformed with the E3332 requirement for "mimicking expected blockage in actual
- 713 conditions".
- 714 Preliminary testing showed that the headloss graph has a 'hockey stick profile", and this was
- confirmed during the official testing. Headloss jumps sharply when the unrestricted open area of the
- net approaches the aperture area at the net entrance, which supports our first hypothesis. Given that
- 717 the aperture size is 1  $ft^2$ , depending on net length and hole opening size, the headloss jump is
- 718 expected to be between  $\sim 60\%$  restricted to  $\sim 90\%$  restricted. This is an important parameter for
- scaling, so we conducted some additional runs, for example 80% restricted, in order to narrow down
- the location of this jump.
- As discussed in Section 4.2, the downstream elevation data was not entirely reliable due to the
- downstream flow patterns changing with net length and hole opening size while the sensor location

remained fixed. This effect was exaggerated during the % restriction testing because now %

- restriction was a third variable factor. This results in hundreds of possible combinations, which could
- not all be analyzed. The problem was overcome by focusing on upstream elevation, which was a
- much more stable reading.

## 727 4.4.1 Calculating Percent Restriction

ASTM E3332 requires restricting a certain percentage of the open area for this test. Using the

assumption that the net forms a cylinder as it fills, the % restriction can be calculated in terms of
length blocked. For example, a 2' long net has an open length of 20", because the top 4" is used to

role rengin blocked. For example, a 2 roling net has an open length of 20 , because the secure it to the frame, so a 10% restriction would be 2", 50% would be 10", etc.

- 732 In order to achieve the different levels of restriction in the different length nets, a large number of
- foam discs, 2" thick and 12" in diameter were cut. These were then stacked into cylinders with the

required height and then wrapped in plastic garbage bags to form plugs of different lengths, as shown

- in Figure 17. The appropriate length of plug was then inserted into the net to get the required %
- restriction. Figure 18 is an example of a 70% plugged 4FT 5 MM net during a run.
- 737
- 738
- 739
- 740
- 741
- 742
- 743



Figure 18 – Top View of % Restriction Test Run



## 749 4.4.2 Percent Restriction Test Results

Tests were conducted on all 6 net length and mesh size combinations (2FT 5MM, 2FT HI, 2FT IN,

4FT 5MM, 4FT HI, 4FT IN), at a minimum of 5 % restrictions: 10, 30, 50, 70 & 90%. Raw data can
be found in Appendix V. In most cases several other conditions were tested in order to find the %

restriction at which the headloss increased sharply. Each net configuration and % restriction was

tested at 5 flows. This exceeds the requirement of 3 flows in E3332 but was appropriate given the

755 headloss behaviour we observed.





#### Figure 20 – 2FT HI Net % Restriction Test



770

Although the lines in Figure 19 and Figure 20 all start flat then rise sharply up, they clearly illustratethe expected trends:

- 1. Headloss is greater at higher flow rates
- Headloss is stable at low precent restriction then rises rapidly at an inflection point at a critical available open area.

In Figure 21-25, the data also follows the expected trends, though at the higher flow rate, the headloss data is more erratic, going up and down instead of rising steadily. Looking at the upstream data in Figure 25, which is Figure 21 with upstream elevation (h1) data instead of headloss ( $\Delta$ h) data, this anomaly disappears, and the data looks exactly as expected. The same is true for all the other figures but they are omitted for brevity. This is consistent with our observation that the downstream elevation data is problematic.

- 782
- 783
- 784
- 785
- 786
- ----
- 787
- 788
- 789





Figure 22 – 4FT 5MM Net % Restriction Test











## 802 **4.4.3 Discussion of Percent Restriction Results**

The second phenomenon hypothesized in Section 4.4 is that the inflection (bypass) point should be at the same mesh open area, regardless of net length. Initially this hypothesis was tested looking at the % restriction data in Section 4.4.2, but it became clear that the nets were stretching a little. In addition, the hypothesis that the open area would be constant meant that the critical percent restriction would be a function of net length, adding a confounding variable. This makes the % restriction data a poor metric for nets.

809 To overcome this limitation the unblocked length at bypass, which we will refer to as the Critical

810 Unblocked Length (CUL), was chosen as the parameter for analysis and it was measured directly in

811 each of the runs. In other words, instead of measuring the blocked area from the bottom of the net,

812 which is what % restrictions does, we measured the unblocked area from the top of the net. The

unblocked length for the different configurations at the design velocity of 5 ft/s is shown in Table 8.

814 Given the large amount of raw data, unblocked length data is not included here but can be found in

815 Appendix VI.

816

Table 8 – Critical Unblocked Length at Bypass @ 5 ft/s

	2FT	4FT
5MM	2.5"	5.75"
HI	4"	4.25"
1IN	3.5"	3.75"

818 Under the basic hypothesis that the inflection occurs when the unblocked area of the net is the same

819 as the area of the aperture, then the 5MM net should have the greatest CUL since it has the smallest

820 open are per square foot. By the same reasoning the HI would have a shorter CUL and the 1IN net

the shortest CUL. Table 8 shows that this trend holds for the 4FT net and for the 2FT HI and 2FT 1IN nets. The 2FT 5MM data point does not fit the expected trend but it is most likely an outlier.

given that it is very different from any of the other data, and it does not have a physical explanation.

Statistical analysis confirms what looks obvious in Table, CUL is not a function of net length, except
in the 5MM net data. It is expected that this is due to the sensor placement issue described in Section
3.1. Since the values in Table 8 are a single point, they could not be compared using a simple t-test.
Instead, the CUL vs flow curves were analyzed using ANCOVA. The results of the ANCOVA are

given in Table 9.

829

Table 9 – ANCOVA of Critical Unblocked Length (CUL) vs. Flow Data

Configuration	p for Intercept	p for Length	p for Flow
5MM	0.17	0.03	0.004
HI	0.20	0.46	0.00003
1IN	0.71	0.61	0.0014

830

831 The values in bold indicate that the variable is significant, and we reject the null hypothesis that the

variable is not a function of hole opening size. This data suggests that critical unblocked length is a

function of flow for all mesh opening sizes, but it is only a function of length for the 5 MM net. The data for the 2FT 5MM is an outlier and based on the preponderance of evidence it can be discounted, leading to the conclusion that unblocked length is not a function of net length, which makes physical

836 sense.

To be conservative, the larger of the two CUL values in Table 7 will be used and the final data is shown in Table 10.

839

Table 10 – Unblocked Length at Bypass, 5 ft/s (CUL)

	L (in)
5MM	5.75
HI	4.25
1IN	3.75

840

To scale this data, and to be consistent with the reporting requirements of the standard, it is useful to convert CUL back into percent restriction at bypass. This was done by dividing the CUL by the starting length of the net. In order to simplify the claim with respect to % restriction, StormTrap decide to make the unblocked length at bypass the same for every mesh opening size and choose the largest value, 5.75" and rounded it to 6". This is conservative in that StormTrap is claiming a lower capacity than is supported by the data. The results are shown in Table 11.

847

Net length (ft)	Critical % Restriction
2	75%
4	88%
6	92%
8	94%

#### Table 11 – % Restriction at Bypass, 5 ft/s Flow

850

851

#### 852 4.4.4 Hydraulics Bypass

As discussed in Section 4.3.5, the system would be expected to behave as a weir once it goes into bypass. This was not confirmed because testing was stopped at the point of bypass.

## 855 4.5 Mass Loading (Trash Removal) Testing

Trash removal testing was conducted in accordance with section 9.3 of ASTM E3332. Once again tests were done, in triplicate, with 6 net configurations. Testing was also expanded to look at the effect of an optional grate installed. The grate was not included in prior tests since it sits above the top of the frame and does not impact the Headloss or % Restriction tests significantly.

860 The artificial trash to be used was blended under the scrutiny of the third-party observer, according to

the recipe in Table 1 of ASTM E3332-22, "Standard Test Method for Determining Trash and/or

862 Debris Capture Performance of Stormwater Control Measures." The trash recipe is shown in Table

- 863 12.
- 864 865

#### Table 12 – Standard Trash Blend

Component	Description	Dimensions ±10 %	% by Dry Mass
Cigarette Filter	regular cigarette filters (ex. OCB brand) ~0.32 oz (9.15 g)/100 filters	0.28 in. (7 mm) diameter by 0.59 in. (15 mm)	14
Disposable wipes	Standard baby wipes	7.5 in. by 2 in. (19 cm by 5 cm)	17 <mark>4</mark>
Wood	Popsicle sticks	4.3 in. by 0.37 in. by 0.08 in. (11 cm by 0.95 cm by 0.2 cm)	11
Plastic-Moldable	PET/ PETE plastic, 0.01 in. – 0.02 in. (0.3 – 0.5 mm) thick, cut in strips	3.5 in. by 1.0 in. (9 cm by 2.5 cm)	23
Plastic-Film	Plastic shopping bag split in half and cut in strips	15.7 in x 3.1 in (40 cm x 8 cm)	8
Cardboard/Chipboard	Cardboard box cut in strips	9 in. by 1 in. (23 cm by 2.5 cm)	10
Cloth	Cotton linen fabric cut in strips	13.8 in. by 2 in. (35 cm by 5 cm)	6
Metal – Foil, Molded	Rigid aluminum, 0.01 in. – 0.02 in. (0.3- 0.5 mm) thick, cut in strips	4 in. by 1 in. (10 cm by 2.5 cm)	7

<sup>A</sup> Disposable wipes can be weighed as they come from the package, drying is not necessary.

#### 866

The artificial trash was blended onsite and sealed upon completion of blending. During testing, the seals were removed only by the observer and the trash was immediately manually transferred into 5gallon pails. Upon completion of each test run, any unused trash was re-sealed by the observer.

- 870 Once a pail was created and the dry weight confirmed by the observer, it was conditioned by adding
- 871 water to the bucket and sealing the bucket using a lid for at least 10 minutes prior to addition to the
- test channel. Trash addition was manual, the bucket was poured into the channel as slowly and
- 873 steadily as practical.

## 874 4.5.1 Artificial Trash QC

Not all of the items in the trash recipe can be purchased directly. A few of them, specifically the

plastics, the cardboard, the cloth and the metal need to be cut to size. This introduces a source of

877 variability that is not addressed in the standard. For this testing the decision was made to test the

878 incoming material based on the requirements of the Acceptance Quality Limit (AQL) Chart, which is

made up of two tables. They are also often referred to as the ANSI/ASQ Z1.4 tables. This is a

880 standard procedure for quality control (QC) of incoming materials. Copies of the charts appear in

881 Appendix VII.

682 Given that nature of the testing and materials, the inspection level chosen was AQL level: General

883 Inspection Level I. A defect was defined as a dimension falling outside the requirements listed in

Table 1, 2 or 3 of ASTM E3332 and all defects were considered major for the sake of the AQL table.

885 Minor or critical defects did not seem relevant in the context of this test.

886 In addition to prescribing the Inspection Level, The AQL criteria requires an acceptance level and a

batch size in order to determine how many incoming samples must be tested and how many defectsare allowed. This information is listed in Table 13. Note that batch size was estimated based on the

889 mass of some sample pieces and the expected mass required for a test.

890

 Table 13 – AQL Incoming Inspection QC Requirements

	Est. Batch size	Sample Size	Defect limit (≤)
Wipes	3201-10,000	80	5
Plastic – moldable	3201-10,000	80	5
Plastic – film	3201-10,000	80	5
Cardboard	1201-3200	50	3
Cloth	501-1200	32	2
Metal strips	501-1200	32	2

891

892 Inspection of incoming materials all conformed to requirements as outlined per the AQL incoming

893 inspection QC requirements.

## 894 4.5.2 Mass Load Testing Results

895 Mass was added by emptying 5-gallon buckets of conditioned 'trash', in water, into the test channel.

This was done by hand, and the rate was made to be as consistent as possible and the rate of mass

addition was in the range of 2 pounds per minute. All tests lasted 10 minutes, in order to simplify

data collection and analysis, but trash addition was always completed in the first few minutes.

As with prior tests, mass loading was conducted with both net lengths and all three hole opening

900 sizes. All three configurations were tested 3 times. The entire set of runs was then repeated without a

grate installed. Table 14 reports the averages of the three runs, with a grate installed. Table 15

902 reports the averages without the grate. Data for the individual runs can be found in Appendix VIII.

- All tests were run at the design flow rate, 2250 gpm,  $\pm 10\%$ .
- The purpose of the grate is to prevent large objects from getting past the TrashTrap during periods of
  high flows when the net is bypassed. The impact of the grate was not specifically tested and no
  claims will be made about its performance.

907 It was discovered during testing that some components air dried very slowly, specifically the cloth

and cigarette butts. In order to accelerate the drying process material was dried in a commercial dryer

909 on low heat. This did lead to some loss of mass. The amount lost was < 5% in all cases, and it

should be roughly the same for captured and bypassed amounts, so it was neglected when calculating

- 911 precent removal.
- 912
- 913

Table 14 – Average Mass Capture Results – Grate Installed

	Starting Mass (lbs)	Mass of Trash Captured in Net (lbs)	Mass of Trash Captured by Grate (lbs)	Mass of Trash Bypassed (lbs)	Mass Lost on Drying (lb)	% Trash Captured
2FT 5MM	1.60	1.37	0.11	0.08	0.05	85
2FT HI	2.40	1.87	0.12	0.29	0.11	78
2FT 1IN	2.40	1.91	0.09	0.34	0.06	79
4FT 5MM	4.00	3.61	0.15	0.07	0.17	90
4FT HI	6.00	4.67	0.25	0.67	0.41	78
4FT 1IN	6.00	4.74	0.13	0.77	0.36	79

- 914
- 915
- 916
- 917
- 918
- 919

Starting Mass of Mass of **Mass Lost** % Trash Mass Trash Trash on Drying Captured Captured **Bypassed** (**lb**) (lbs) in Net (lbs) (lbs) **2FT 5MM** 1.60 1.38 0.19 0.03 86 2.40 **2FT HI** 1.74 0.59 0.07 73 **2FT 1IN** 1.89 79 2.40 0.43 0.08 **4FT 5MM** 4.00 3.58 0.45 0.06 89 4FT HI 6.00 4.76 1.37 0.14 80 **4FT 1IN** 6.00 4.41 1.49 0.10 73

 Table 15 – Average Mass Capture Results – No Grate

## 923 **4.5.3 Discussion of Mass Load Testing Results**

924 Implementing the protocol described in ASTM E3332 revealed a number of interesting outcomes that

will need to be addressed in the next revision of the standard. One discovery was that the test and

reporting requirements are not always consistent with each other, leading to some necessarydeviations.

928 The biggest issue is that the protocol requires gathering mass data during a run, but this is not

929 possible because the captured trash cannot be removed and dried in real time. This requires some

930 deviation from the reporting requirements in Section 9.3.7 of the protocol. These are outlined in

931 Section 4.5.3.1 below.

932 The issue with not being able to measure mass in real time is that it means that the end point of the 933 test is not clearly defined. In our case we continued to empty the last bucket once the system went 934 into bypass. This resulted in % removal numbers in the 70-90 range when, in fact, removal was

935 100% up until the point of bypass. The final number is just a function of how much trash was left in

936 the bucket once bypass started.

937 This number will not be constant and that explains the variation in percent capture in Table 14 and

Table 15. In retrospect, we should have stopped as soon as the first couple peanuts bypassed, then

939 weighed the unused influent trash separately to do our calculations. Given this issue, we will not

940 make a % removal performance claim but will claim a mass captured instead.

A second discovery was that the Styrofoam peanuts were always the first material to bypass. This creates a challenge in interpreting results for the real world because peanuts weigh very little. This means they have a minimal impact on the % captured data, which is mass based, but they have a large impact on perceived failure because they are visually obvious. Finally, there is the issue of reporting the results in terms of dry mass. The trash components are all relatively light when dry so, while the dry mass is a reproducible way to compare results, it is not very informative in terms of what users can expect in the field. Section 4.5.3.2 addresses this by providing bulk density data for a wetted

948 trash mixture.

- 949 Figure 26 shows the beginning of bypass during a 2FT 5MM net test. You can see the last of the
- 950 second bucket of trash being added to the channel and peanuts flowing over the grate. Closer
- 951 inspection will reveal that the peanuts have clogged the grate at this point.

#### Figure 26 – Bypass of 2FT 5MM Net



953

954

## 955 4.5.3.1 Deviations from Mass Capture Test Procedure in ASTM E3332

956 Section 9.3.7.5 requires recording the total mass added at the point of bypass. This would require 957 stopping the test to recover and dry the mass, then restarting the test to go to failure. The best we can 958 do is claim that the mass added at bypass equals the total mass in the net. In other words, assume no 959 mass was captured after bypass. This is not true, some of the heavier components would still be 960 captured, but it is conservative.

Section 9.3.7.6 requires a graphical representation of mass load versus headloss. As with Section
9.3.7.3 and 9.3.7.5, this would require measuring the mass added in real time and this is not possible.
A good approximation can be obtained by looking at the headloss from the % restriction testing and
converting the % restriction to a mass based assuming the total mass captured equals 100% blocked.
In other words, repeating Figures 19-24 with the % restriction on the x-axis changed so that 100%
restriction = the appropriate mass in Table 12.

## 967 4.5.3.2 Wetted Trash Mass Calculations

In order to determine a conversion factor from dry trash to wet trash we filled three 5-gallon buckets with trash and then topped them up with water and let them sit for 90 minutes. The bucket volumes

970 were 0.68  $\text{ft}^3$ . The buckets were then drained and the wet trash weighed. The results are shown in

971 Table 16.

	Bucket #1	Bucket #2	Bucket #3	Average
Dry trash wt (lbs)	1.78	1.38	1.50	1.55
Wet trash wt. (lbs)	5.64	4.58	4.94	5.05
Ratio				3.26

974 This ratio was used, along with the normalized mass data in Table 19 in the section on scaling,

975 Section 5.1, to generate the performance claims for the TrashTrap.

## 976 4.5.4 Hydraulic Bypass

As discussed in Section 4.3.5, the system would be expected to behave as a weir once it goes into bypass. This was not confirmed because testing was stopped at the point of bypass.

## 979 **4.6 Scour**

980 Scour testing was conducted in accordance with section 9.5 of ASTM E3332. Once the 50% capacity 981 level was determined by mass capacity testing, nets were pre-loaded to 50% capacity with 982 conditioned trash. The flow was ramped up to an average of 9.77 cfs, across all six tests, within 3 983 minutes and then ran for a minimum of 5 minutes. Residence time for the net is not really defined but 984 it can be estimated by assuming the net is a cylinder 1 ft<sup>2</sup> in diameter and either 2 or 4 ft long. This 985 gives a volume of 2 or 4 ft<sup>3</sup> and, at 10 cfs, residence time of 0.2 or 0.4 seconds so 5 minutes is

986 significantly longer than 5 residence times.

987 The hypothesis was that a half full net would not scour, since the incoming water would be pushing 988 any captured material back into the net. No bypass was observed in any of the tests, supporting this 989 hypothesis. The flow rates for all the tests are shown in Figure 27. Note that the hump at ~2 minutes 990 in all the lines is an artifact of the way Excel draws line graphs. It should be a flat line, there is no 991 local maximum in the data. There is one missing data point at minute 1 in the 2FT HI run. The data 992 point does not appear in the log file for the flow meter so it must have been a brief malfunction. This 993 "explains" why the curve from 2-3 minutes is flat for 2FT HI but is a maximum for all the other 994 datasets.

995

- 997
- 998
- 999
- 1000
- 1001
- 1002
- 1003

**Figure 27 – Flow Rate During Scour Tests** 



# 1007 5.0 Additional Considerations

The testing was conducted on a small-scale system in order to keep the flow requirement manageable.
In order for the data to have practical value it needs to be scaled. Scaling in terms of hydraulics is
discussed in section 4.3.7. Section 5.1 addresses scaling for performance.

## 1011 **5.1 Scaling performance**

1012 Assuming a constant bulk density, which is valid for the purpose of this testing, mass capacity should

1013 scale with volume. The test system had a constant cross section area of 1 ft<sup>2</sup>. The mass captured can

1014 be divided by the length of the net to give a normalized mass/volume in  $lbs/ft^3$ . It is acknowledged

1015 that the net will not form a perfect cylinder, so the volume is approximate.

1016Table 17 and Table 18 show the calculated mass capacity of the tested nets in lbs/ft, with and without1017a grate.

Table 17 – Normalized Mass	Capacity – Net + Grate
----------------------------	------------------------

Opening Size	2 FT Net Mass Capacity (lb/ft <sup>3</sup> )	4 FT Net Mass Capacity (lb/ft <sup>3</sup> )
5 MM	0.85	0.90
HI	0.78	0.78
1 IN	0.79	0.79

#### Table 18 – Normalized Mass Capacity – Net Only

Opening Size	2 FT Net Mass Capacity (lb/ft <sup>3</sup> )	4 FT Net Mass Capacity (lb/ft <sup>3</sup> )
5 MM	0.86	0.89
HI	0.73	0.80
1 IN	0.79	0.73

1021

1022 There is not enough data for a robust ANCOVA but inspection of the data shows that the mass 1023 capacity is not a significant function of the grate or the net length. This allows the results to be 1024 condensed as shown in Table 19. These are the numbers to be used for scaling.

1025

#### Table 19 – Normalized Mass Capacity – Combined Data

Opening Size	Avg. Mass Capacity (lbs./ft <sup>3</sup> )
5 MM	0.88
HI	0.77
1 IN	0.78

1026

1027 For example, an 8' long net with a 30" x 30" opening and 5 MM holes would have a cross-section

1028 area (assuming the net forms a cylinder) of  $4.91 \text{ ft}^2$  and a volume of  $39.3 \text{ ft}^3$ . This would result in a 1029 mass capacity of 35 lbs. of dry trash of the same composition prescribed in E3332.

1030 This number is useful for comparing different sizes and types of system, since dry mass is a

1031 reproducible value, but it does not help with maintenance since dry mass is practically impossible to

1032 measure in an installed system. A practical method for determining the maintenance capacity is

1033 described in section 5.1.1.

## 1034 5.1.1 Scaling Maintenance Capacity

1035 The mass capacity determined in section 5.1 is useful for comparing technologies that have been

1036 tested according to ASTM E3332, but for determining the effective capacity in the field, volume

1037 capacity is more useful. This is because mass is highly variable and not easily measured in the field.

1038 TrashTraps have different opening sizes and net lengths so in principle, scaling needs to consider

length, width and height, where length is measured the flow direction and height is perpendicular to

1040 the ground. However, it was shown in Section 4.3.4 that net length is not a factor in scaling. As long

as there is a critical open area available, the length of the net beyond the critical length does not

1042 matter. Thus, TrashTrap scaling is based on the opening area, width x height, not the net volume.

1043 TrashTraps are scaled geometrically in order to maintain a maximum design flow velocity of 5 ft/s.

1044 This velocity limit ensures the physical integrity of the system at maximum load and flow. Since all

1045 TrashTraps have the same maximum velocity, they have the same unblocked length as shown in

1046 Table 20, since this capacity was determined at the maximum velocity.

1047 In order to use the unblocked length for scaling it needs to be normalized in terms of the opening

area. The system tested had a 1" x 1" opening. To convert this to a hydraulic radius,  $R_h$ , the equation is:

#### 1050 Equation 19 $R_h = A/P$

1051 Where A = the area of the opening and P equals the perimeter.

1052 A 1 ft x 1 ft square has an area of 1 ft<sup>2</sup> and a perimeter of 4 ft, giving it a hydraulic radius of 0.25 ft.

1053 Assuming that, during flow, the net has the same hydraulic radius as the opening and the unblocked

length gives the critical unblocked area/square foot of opening shown in Table 20.

#### 1055

## Table 20 – Unblocked Area/ft<sup>2</sup> of Opening for Different Hole Sizes

	Unblocked length	Unblocked area/sq ft of opening
	(ft)	(dimensionless)
5 MM	0.479	0.120
HI	0.354	0.089
1 IN	0.3125	0.078

1056

1057 The numbers in the second column of Table 20 can be used to determine the critical unblocked of all 1058 net openings as a function of hole size. These are shown in Table 21.

1059

#### Table 21 – Critical Unblocked Area for Different Net Opening Sizes

Net Opening Size	Opening area	Critical Unblocked Area 5 MM	Critical Unblocked Area HI	Critical Unblocked Area 1IN
	(ft <sup>2</sup> )	(ft <sup>2</sup> )	(ft <sup>2</sup> )	(ft <sup>2</sup> )
24" x 24"	4.00	0.480	0.356	0.312
30" x 30"	6.25	0.750	0.556	0.488
36" x 36"	9.00	1.08	0.801	0.702

1060

1061 This can then be applied to each available net length in terms of a % volume capacity. Due to the

1062 large number of combinations, each of the hole sizes is a separate table.

1063

#### Table 22 – Capacity of Nets with 5 MM holes

Net Opening Size	Net Length (ft)	Hydraulic Radius (ft)	Net Area (ft <sup>2</sup> )	Critical Unblocked Area (ft <sup>2</sup> )	Net Capacity before Maintenance
24" x 24"	2	0.500	6.28	0.48	92%
24" x 24"	4	0.500	12.57	0.48	96%
24" x 24"	6	0.500	18.85	0.48	97%
24" x 24"	8	0.500	25.13	0.480	98%
30" x 30"	2	0.625	7.85	0.750	90%

Net Opening Size	Net Length (ft)	Hydraulic Radius (ft)	Net Area (ft <sup>2</sup> )	Critical Unblocked Area (ft <sup>2</sup> )	Net Capacity before Maintenance
30" x 30"	4	0.625	15.71	0.750	95%
30" x 30"	6	0.625	23.56	0.750	97%
30" x 30"	8	0.625	31.42	0.750	98%
36" x 36"	2	0.750	9.42	1.08	89%
36" x 36"	4	0.750	18.85	1.08	94%
36" x 36"	6	0.750	28.27	1.08	96%
36" x 36"	8	0.750	37.70	1.08	97%

## Table 23 – Capacity of Nets with HI Holes

Net Opening Size	Net Length (ft)	Hydraulic Radius (ft)	Net Area (ft <sup>2</sup> )	Critical Unblocked Area (ft <sup>2</sup> )	Net Capacity before Maintenance
24" x 24"	2	0.500	6.28	0.356	94%
24" x 24"	4	0.500	12.57	0.356	97%
24" x 24"	6	0.500	18.85	0.356	98%
24" x 24"	8	0.500	25.13	0.356	99%
30" x 30"	2	0.625	7.85	0.556	93%
30" x 30"	4	0.625	15.71	0.556	96%
30" x 30"	6	0.625	23.56	0.556	98%
30" x 30"	8	0.625	31.42	0.556	98%
36" x 36"	2	0.750	9.42	0.801	92%
36" x 36"	4	0.750	18.85	0.801	96%
36" x 36"	6	0.750	28.27	0.801	97%
36" x 36"	8	0.750	37.70	0.801	98%

Net Opening Size	Net Length (ft)	Hydraulic Radius (ft)	Net Area (ft <sup>2</sup> )	Critical Unblocked Area (ft <sup>2</sup> )	Net Capacity before maintenance
24" x 24"	2	0.500	6.28	0.312	95%
24" x 24"	4	0.500	12.57	0.312	98%
24" x 24"	6	0.500	18.85	0.312	98%
24" x 24"	8	0.500	25.13	0.312	99%
30" x 30"	2	0.625	7.85	0.488	94%
30" x 30"	4	0.625	15.71	0.488	97%
30" x 30"	6	0.625	23.56	0.488	98%
30" x 30"	8	0.625	31.42	0.488	98%
36" x 36"	2	0.750	9.42	0.702	93%
36" x 36"	4	0.750	18.85	0.702	96%
36" x 36"	6	0.750	28.27	0.702	98%
36" x 36"	8	0.750	37.70	0.702	98%

Table 24 – Capacity of Nets with 1 IN Holes

1072

For the purpose of making a simple, practical, claim StormTrap will choose a Net Capacity of 85%by volume.

1075

## 1076 **6.0 Design Limitations**

- 1077 The StormTrap TrashTrap is an engineered system designed to meet site-specific
- requirements. Design should be completed in consultation with StormTrap. Some general designparameters and limitations are listed below.
- 1080 Maximum Treatment Flow Rate

1081 The maximum treatment flow rate (MTFR) for StormTrap TrashTrap is based on water velocity so it

- 1082 varies with system dimensions. StormTrap recommends that systems should be sized for a flow
- 1083 velocity of  $\leq 5$  ft/s at the net opening.
- 1084 Maintenance Requirements
- 1085 TrashTrap systems should be inspected and maintained following the recommendations and
- 1086 guidelines included in the TrashTrap Manufacturer's Instruction Manual available at:
- 1087 <u>https://stormtrap.com/products/trashtrap/</u>.
- 1088
- 1089

- 1090 Installation Limitations
- 1091 StormTrap provides contractors with detailed installation and assembly instructions prior to delivery.
- *Configurations*
- 1093 TrashTrap is available in 3 basic configurations: in-line, end-of-pipe and floating. The primary
- 1094 difference between them is how the net and frame are mounted in the flow. All configurations use
- 1095 the same nets and can be expected to behave as described in this report.

# Jason Wiesbrock, P.E.

#### **Vice President**

Joined Spaceco: 2005 Years of Experience: 29

As Vice President, Mr. Wiesbrock is responsible for the management of Spaceco's Morris office and is responsible for management and oversight of infrastructure, transportation, and industrial, commercial, and residential site development projects for both public and private sector clients. He also supervises a support staff including Senior Project Managers, Project Managers, Design Engineers, and CAD operators and is responsible for business development activities. His duties include oversight and design of grading and utility layout, earthwork analysis, cost estimation, stormwater management, permitting, and construction observation.

#### **Project Experience**



#### Creekside Estates – Channahon, IL

A 33-acre luxury residential development including 112 duplexes on 56 individual lots.



#### Towne Place Suites – Minooka, IL

The development of a four story, 87-room hotel on 3 acres of land.



## G.E. Appliances – Morris, IL

A 180-acre development including a 1.2-million square foot CSX rail-served distribution facility.



#### EDUCATION

 Bachelor of Science | Civil Engineering University of Illinois, 1995

#### REGISTRATION

- Professional Engineer
  - Illinois | 062-057654 (2004)

#### CAREER SUMMARY

- 2005 Present
- Spaceco, Inc.
- 1996-2005
- Jacob & Hefner Associates, Inc. 1995-1996
- Spaceco, Inc.

#### AFFILIATIONS

- Grundy County Chamber of Commerce
- Grundy Economic Development Council
- I-39 Logistics Corridor Association
- Illinois Valley Area Chamber of Commerce
- Village of Lostant Zoning Board, Chairman
- Lostant Fire Protection District, Board of Directors, Treasurer
- Lostant Volunteer Fire Department, Certified Fire Fighter II
- Hope Township, Board of Directors



#### Jason Weisbrock, PE Vice President, Spaceco Inc. 224½ N. Liberty St, Morris, IL 60450

Requirement	Experience
hydraulic testing, water quality monitoring and	Designed/reviewed the stormwater
analytical measurements	management (ponds and storm sewers) for
	multiple project in multiple locations in
	Chicagoland. Most recent is the 1.3-million
	square foot warehouse building with
	associated stormwater management,
	semi/tractor-trailer/auto parking, and utilities.
experimental design and setup	Multiple projects where "wet" and "dry"
	stormwater management facilities were
	evaluated. Most recently an industrial
	development in unincorporated Grundy
	County, IL.
sampling methods, handling sample security	In years past I inspected various project sites
(i.e., chain of custody)	for SWPPP compliance during construction.
task documentation and data management	Multiple projects in the Chicagoland area
	where I've designed and/or managed projects
	from the frontend land surveying to the
	engineering design, to the construction
	staking, and through the as built/record
	drawing stage. Currently reviewing design
	plans and stormwater calculations for a
	project in Channahon, IL prepared by a
	different firm for submittal to the governing
	agencies.
Knowledge of QA/QC	I QA/QC multiple projects annually that my
	staff prepares. A recent one is the Tractor
	Supply Company site in Beach Park, IL.
Knowledge of ASTM	Designed/reviewed multiple projects using
	IDOT and ASTM standards. Current project is
	US Rt. 6 roadway widening in Morris, IL.
Knowledge of laboratory or field testing or	I review all existing field data (topography,
monitoring procedures	utilities, Geotech reports, wetland reports,
	etc.) prior to starting the site design. Most
	recently a proposed 1.2-million square foot
	warehouse in Coal City, IL.

Supplement to resume

- 1125
- 1126
- 1127
- 1128
- 1120
- 1129

## Appendix II – ANCOVA Discussion

- 1131 The basic method looks at the dependent (y) variable as a function of a series of multiple dependent
- 1132 variables with a covariate. In Section 3, the analysis is headloss versus flow with run number or net
- 1133 type as the covariant. The ANCOVA tests the null hypothesis,  $H_0$ , that the datasets are the same. It
- 1134 is fundamentally a combination of regression and ANOVA that allows the identification of the source
- of error. If the error is mainly due to the model, then headloss is a function of flow, if not then the
- 1136 error is either random and headloss is not a function of flow or headloss is a function of flow and one
- 1137 or more covariant.
- 1138 The test statistic for regression and ANOVA is "F". Excel outputs "Significance F" which is the
- 1139 same as p value. If  $p \ge \alpha$  then the covariate is not significant, the null hypothesis is accepted, and the
- 1140 three data sets are statistically the same. Unless otherwise noted,  $\alpha = 0.05$  for all tests.
- 1141 (Note: If the ANCOVA shows that  $H_0$  must be rejected, further work is required to determine which 1142 dataset is different, in other words which covariant is a factor.)
- 1143 The easiest way to implement ANCOVA in Excel is necessary to use n-1 dummy variables. In the
- 1144 case of the Hydraulics runs there are three series of runs so N = 2 and 2 dummy variables are
- 1145 required. In this report Series 1 was coded d1 = 1, d2 = 0, series 2 was coded d1 = 0 d2 = 1 and series
- 1146 3 was coded d1 = 0, d2 = 0. This makes Series 3 the reference curve, so the results are compared to
- 1147 the Series 3 curve. If neither Series 1 nor Series 2 is significantly different from Series 3 then all
- 1148 three curves are, statistically, the same.